

<b>Program:</b>	MaineHousing Heat Pump Program (MHPP)	<b>MHN #</b>	2021-06
<b>Issued by:</b>	MaineHousing Energy and Housing Services	<b>Effective Date:</b>	10/1/2021

**MaineHousing Notice 2021-06 is being issued to notify CAAs of a temporary change to the HSPF 13 or greater specification.**

### 1. Reference MHPP Guide

*Reference:* MHPP Guide, Section 7D (2)

(Equipment must be a 9,000 or 12,000 BTU heat pump system with a HSPF of 13 or greater)

Temporary change – MaineHousing is granting a waiver to allow for the installation of heat pumps with a HSPF of 12.5 or greater until **12/31/2021**. Heat pumps must meet all other MaineHousing Heat Pump Program (MHPP) specifications. Heat pumps with a HSPF of 12.5 can only be installed on jobs that have been work ordered on or before **12/31/2021**.

### 2. Notice Contact

Troy Fullmer, *Manager of HEAP* – 207-624-5720 – [tfullmer@mainehousing.org](mailto:tfullmer@mainehousing.org)

Brad Fenton-Snell – *Weatherization Program Officer* – 207-626-4639 - [bfentonsnell@mainehousing.org](mailto:bfentonsnell@mainehousing.org)

DeAnna Trask – *Weatherization Program Officer* – 207-624-5726 – [dtrask@mainehousing.org](mailto:dtrask@mainehousing.org)

---