

Program:	MaineHousing Heat Pump Program (MHPP)	MHN #	2021-10
Issued by:	MaineHousing, Energy and Housing Services	Effective Date:	01/01/2022

This MaineHousing Notice is being issued to notify CAAs of a temporary change to the HSPF 13 or greater specification.

1. Reference MHPP Guide

Reference: MHPP Guide, Section 7D (2)

(Equipment must be a 9,000 or 12,000 BTU heat pump system with a HSPF of 13 or greater)

Temporary change – MaineHousing is granting a waiver to allow for the installation of heat pumps with a HSPF of 12.5 or greater until **05/31/2022**. Heat pumps must meet all other MaineHousing Heat Pump Program (MHPP) specifications. Heat pumps with a HSPF of 12.5 can only be installed on jobs that have been work ordered on or before **05/31/2022**.

2. Notice Contact

Troy Fullmer, *Manager of HEAP* – 207-624-5720 – tfullmer@mainehousing.org

Brad Fenton-Snell – *Weatherization Program Officer* – 207-626-4639 - bfentonsnell@mainehousing.org

DeAnna Trask – *Weatherization Program Officer* – 207-624-5726 – dtrask@mainehousing.org
